





Taco Booster Submittal Information



Pump Model	A	B		Cmin	Cmax	Dmin	Dmax
		150#	300#				
1VR	7.0	37.0	38.5	12.3	33.5	11.1	
3VR					31.7	11.1	13.1
6VR					41.8		16.1
10VR	7.5	30.5	37.0	13.7	29.9		20.9
15VR				16.3	43.8		
20VR					40.0	19.8	
30VR	8.1	41.0	43.5	17.9	48.9	13.7	25.0
45VR	9.5		44.0	26.7	47.0	15.2	27.6
65VR		46.5	49.0	29.0	44.5		
95VR					40.9	17.9	

Booster Info Section	
Project:	
Rep.:	
Model:	
Pump Details:	
Total Package Flow (USGPM):	
Total Package Head (ft):	
Sequence of Operation:	
Header Size:	
Motor Enclosure:	
Motor Electric:	
Integrated Drive Controller Enclosure: UL type	
UL/CSA Labelled	
Dual DC-Link chokes (5% AC line reactor)	
Protocols (Standard): BACnet, Modbus RTU, N2 Metasys, FLN Apogee, FC Protocol	

NOTES:

1. Not to be used for construction/piping unless certified
2. Control Panel arrangement/design may vary
3. Dimensions are approx.
4. Maximum operating pressure is

Drafter Remarks:

Model:

DRW BY:	DATE:	CHKD BY:	DATE:
J.D	09.26.2019	N/A	N/A
TOLERANCES UNLESS OTHER SPECIFIED			
Dec: ±0.06	Frac: 1/16	Angle: 1/2"	SCALE: NTS
REV	SIZE	TAG:	
B	A4		